

MADHYA PRADESH POWER TRANSMISSION COMPANY LIMITED
STATE LOAD DESPATCH CENTER, NAYAGAON, RAMPUR, JABALPUR
Telephone: (0761) 2702740/2702748 Fax :(0761) 2664343
E-mail sldcmpjbp@gmail.com

SUB :- APPROVED SHUT DOWN OF TRANSMISSION ELEMENTS IN 546th WR OCCM FOR THE PERIOD 01.09.21 TO 30.09.21

Annexure 3.2

Sr. No	Request Type	OCC Number	Name of Requesting Agency	Line / Element	D/C	reason	From	time	to	Time	Remarks	OCC-Remarks
1	PLANNED	OCC_546	MP_SLDC	400 kV Bhopal- Itarsi(PG) Ckt-I & II	D	Auto mode to non-auto mode for replacement work of earth wire by OPGW on 400 kV Bhopal- Itarsi(PG) Ckt-I & II	1-Sep-21	07:00	30-Sep-21	19:00		
2	PLANNED	OCC_546	MP_SLDC	400KV/220KV JABALPUR-ICT-1	C	FOR BAY EQUIPMENT MAINTENANCE AND TESTING WORK	2-Sep-21	9:00	3-Sep-21	17:00		
3	PLANNED	OCC_546	MP_SLDC	400KV-SATPURA-INDIRASAGAR-1	D	For Replacement of HCB Isolator of 400 KV SARNI-ISP Feeder	2-Sep-21	9:00	2-Sep-21	18:00	400KV Sami- Indira Sagar will remain out during shutdown	
4	PLANNED	OCC_546	MP_SLDC	400KV Bus Reactor II at 400KV s/s satpura	D	For Replacement of HCB Isolator of 400 KV Bus Reactor-II	3-Sep-21	09:00	3-Sep-21	18:00	400KV Bus- Reactor II will remain out during shutdown	
5	PLANNED	OCC_546	MP_SLDC	400KV TBC AT 400KV S/S INDORE	D	FOR POST MONSOON MAINTENANCE & TESTING WORK	3-Sep-21	09:00	3-Sep-21	18:00		
6	PLANNED	OCC_546	MP_SLDC	400KV-BHOPAL-MP- BDTCL-1	D	FOR BAY EQUIPMENT MAINTENANCE AND TESTING WORK	3-Sep-21	09:00	3-Sep-21	17:00		BDTCL will also take the opportunity for doing minor maintenance work if MPPTCL is availing the shutdown.
7	PLANNED	OCC_546	MP_SLDC	400KV BUS COUPLER AT 400KV S/S INDORE	D	FOR POST MONSOON MAINTENANCE & TESTING WORK	4-Sep-21	9:00	4-Sep-21	18:00		
8	PLANNED	OCC_546	MP_SLDC	400KV SARNI- SEONI	D	For the Re-alignment of HCB Isolator of 400 Kv Sarni-Seoni feeder	4-Sep-21	09:00	4-Sep-21	18:00	400KV Sarni- Seoni Feeder will remain out during shutdown	
9	PLANNED	OCC_546	MP_SLDC	400KV ICT with BAY at 400KV s/s satpura	D	Shifting of 315 MVA 400/220/33 Kv ICT from Main breaker to Tie breaker	6-Sep-21	09:00	6-Sep-21	11:00		
10	PLANNED	OCC_546	MP_SLDC	400KV ICT with BAY at 400KV s/s satpura	C	Complete Overhauling of 400 kv SF6 gas main circuit breaker of 315 MVA 400/220/33 kv ICT Bay	6-Sep-21	11:00	18-Sep-21	10:00	During the shutdown 315 MVA 400/220/33 KV ICT will remain charged	
11	Additional	OCC_546	MP_SLDC	400KV/220KV JABALPUR-ICT-2	C	FOR BAY EQUIPMENT MAINTENANCE AND TESTING WORK	6-Sep-21	9:00	7-Sep-21	17:00		
12	PLANNED	OCC_546	MP_SLDC	400KV-KATNI-MP-DAMOH-PG	D	FOR LINE MAINTENANCE WORK	6-Sep-21	9:00	6-Sep-21	18:00		
13	PLANNED	OCC_546	MP_SLDC	400KV-MAIN-BUS-2 AT 400KV S/S BINA	C	FOR POST MONSOON MAINTENANCE & PG ISOLATOR MAINTENANCE ACTIVITY	6-Sep-21	00:00	8-Sep-21	00:00		
14	PLANNED	OCC_546	MP_SLDC	400KV BHOPAL-MP- BINA-MP-2	D	FOR BAY EQUIPMENT MAINTENANCE AND TESTING WORK	7-Sep-21	09:00	7-Sep-21	17:00		
15	PLANNED	OCC_546	MP_SLDC	400KV NAGDA-MP-BADNAWAR-MP-2 WITH REACTOR (AT 400KV S/S NAGDA)	D	FOR BAY EQUIPMENT MAINTENANCE AND TESTING WORK	8-Sep-21	08:00	8-Sep-21	18:00		
16	PLANNED	OCC_546	MP_SLDC	400KV-RAJGARH-PG-SSP-1	D	FOR LINE MAINTENANCE WORK	8-Sep-21	8:00	8-Sep-21	18:00		

Sr. No	Request Type	OCC Number	Name of Requesting Agency	Line / Element	D/C	reason	From	time	to	Time	Remarks	OCC-Remarks
17	PLANNED	OCC_546	MP_SLDC	400KV-SAGAR-MP-BINA-PG	D	FOR LINE MAINTENANCE WORK	8-Sep-21	9:00	8-Sep-21	18:00		
18	PLANNED	OCC_546	MP_SLDC	400KV-KIRNAPUR-MP-BHILAI-CG	D	FOR LINE MAINTENANCE WORK	9-Sep-21	09:00	9-Sep-21	18:00		
19	PLANNED	OCC_546	MP_SLDC	400KV-SAGAR-MP-SATNA-PG	D	FOR LINE MAINTENANCE WORK	10-Sep-21	9:00	10-Sep-21	18:00		
20	PLANNED	OCC_546	MP_SLDC	400KV-MAIN-BUS-1 AT 400KV S/S BINA	C	FOR POST MONSOON MAINTENANCE & PG ISOLATOR MAINTENANCE ACTIVITY	13-Sep-21	0:00	15-Sep-21	00:00		
21	PLANNED	OCC_546	MP_SLDC	400KV BHOPAL-MP-ITARSI-PG-2	D	FOR BAY EQUIPMENT MAINTENANCE AND TESTING WORK	14-Sep-21	09:00	14-Sep-21	17:00		
22	PLANNED	OCC_546	MP_SLDC	400KV-RAJGARH-PG-SSP-2	D	FOR LINE MAINTENANCE WORK	14-Sep-21	8:00	14-Sep-21	18:00		
23	PLANNED	OCC_546	MP_SLDC	400KV-SATPURA (SARNI)-SEONI-PG	D	FOR LINE MAINTENANCE WORK	15-Sep-21	9:00	15-Sep-21	17:00		
24	PLANNED	OCC_546	MP_SLDC	400KV-BADNAWAR-MP-RAJGARH-PG-2	D	FOR LINE MAINTENANCE WORK	16-Sep-21	08:00	16-Sep-21	18:00		
25	PLANNED	OCC_546	MP_SLDC	400KV ICT with BAY at 400KV s/s satpura	D	Shifting of 315 MVA 400/220/33 Kv ICT from Tie breaker to Main breaker	18-Sep-21	10:00	18-Sep-21	12:00		
26	PLANNED	OCC_546	MP_SLDC	400KV-KIRNAPUR-MP-SEONI-PG	D	FOR LINE MAINTENANCE WORK	20-Sep-21	09:00	20-Sep-21	18:00		
27	PLANNED	OCC_546	MP_SLDC	400KV-INDIRASAGAR-NAGDA-MP	D	FOR LINE MAINTENANCE WORK	21-Sep-21	8:00	21-Sep-21	18:00		
28	PLANNED	OCC_546	MP_SLDC	400KV-BADNAWAR-MP-RAJGARH-PG-1	D	FOR LINE MAINTENANCE WORK	22-Sep-21	8:00	22-Sep-21	18:00		
29	PLANNED	OCC_546	MP_SLDC	400KV-BHOPAL-MP- BDTCL-2	D	FOR BAY EQUIPMENT MAINTENANCE AND TESTING WORK	22-Sep-21	9:00	22-Sep-21	17:00		BDTCL will also take the opportunity for doing minor maintenance work if MPPTCL is availing the shutdown.
30	PLANNED	OCC_546	MP_SLDC	400KV-MAIN-BUS-1 AT 400KV S/S BADNAWAR	C	FOR BAY EQUIPMENT MAINTENANCE AND TESTING WORK	22-Sep-21	09:00	23-Sep-21	17:00		
31	PLANNED	OCC_546	MP_SLDC	400KV-KATNI-BIRSINGHPUR-PH-1	D	FOR LINE MAINTENANCE WORK	27-Sep-21	9:00	27-Sep-21	18:00		
32	PLANNED	OCC_546	MP_SLDC	400KV-INDIRASAGAR-INDORE-MP-1	D	FOR LINE MAINTENANCE WORK	29-Sep-21	08:00	29-Sep-21	18:00		
33	PLANNED	OCC_546	MP_SLDC	400KV-KATNI-BIRSINGHPUR-PH-2	D	FOR LINE MAINTENANCE WORK	29-Sep-21	09:00	29-Sep-21	18:00		
34	PLANNED	OCC_546	MP_SLDC	220KV INDORE-PG -INDORE-II(JETPURA)-MP-1	D	FOR LINE MAINTENANCE WORK	1-Sep-21	8:00	1-Sep-21	18:00		
35	PLANNED	OCC_546	MP_SLDC	220KV-SATNA(PGCIL)-CHHATARPUR-MP-1	D	FOR LINE MAINTENANCE WORK	2-Sep-21	10:00	2-Sep-21	17:00		
36	PLANNED	OCC_546	MP_SLDC	220KV-KHANDWA-PG-NEPANAGAR-MP-1	D	FOR LINE MAINTENANCE WORK	3-Sep-21	08:00	3-Sep-21	18:00		
37	PLANNED	OCC_546	MP_SLDC	220KV-MEHGAON-MP-AURIYA	D	220KV MAIN BUS SHUTDOWN FOR FIRE WEDGE CONNECTOR INSTALLATION WORK ON 220KV S/S MEHGAON & POST MONSOON MAINTANENECE WORK	3-Sep-21	09:00	3-Sep-21	17:00		
38	PLANNED	OCC_546	MP_SLDC	220KV-MEHGAON-MP-MORENA	D	220KV MAIN BUS SHUTDOWN FOR FIRE WEDGE CONNECTOR INSTALLATION WORK ON 220KV S/S MEHGAON & MAINTANENECE WORK	3-Sep-21	09:00	3-Sep-21	17:00		
39	PLANNED	OCC_546	MP_SLDC	220KV INDORE-PG -INDORE-II(JETPURA)-MP-2	D	FOR LINE MAINTENANCE WORK	4-Sep-21	8:00	4-Sep-21	18:00		
40	PLANNED	OCC_546	MP_SLDC	220KV-MEHGAON-MP-AURIYA	D	220KV MAIN BUS SHUTDOWN FOR FIRE WEDGE CONNECTOR INSTALLATION WORK ON 220KV S/S MEHGAON & POST MONSOON MAINTANENECE WORK	4-Sep-21	09:00	4-Sep-21	17:00		
41	PLANNED	OCC_546	MP_SLDC	220KV-MEHGAON-MP-MORENA	D	220KV MAIN BUS SHUTDOWN FOR FIRE WEDGE CONNECTOR INSTALLATION WORK ON 220KV S/S MEHGAON & POST MONSOON MAINTANENECE WORK	4-Sep-21	09:00	4-Sep-21	17:00		

Sr. No	Request Type	OCC Number	Name of Requesting Agency	Line / Element	D/C	reason	From	time	to	Time	Remarks	OCC-Remarks
42	PLANNED	OCC_546	MP_SLDC	220KV-KHANDWA-PG-CHHEGAON-MP-1	D	FOR LINE MAINTENANCE WORK	6-Sep-21	08:00	6-Sep-21	18:00		
43	PLANNED	OCC_546	MP_SLDC	220KV-MALANPUR-MP-MORENA	D	FOR BAY EQUIPMENT MAINTENANCE AND TESTING WORK	6-Sep-21	10:00	6-Sep-21	17:00		
44	PLANNED	OCC_546	MP_SLDC	220KV-PANDHURNA-MP-KALMESHVAR-MH	D	FOR LINE MAINTENANCE WORK	6-Sep-21	09:00	6-Sep-21	18:00		
45	PLANNED	OCC_546	MP_SLDC	220KV-MALANPUR-MP-AURIYA	D	FOR LINE MAINTENANCE WORK	7-Sep-21	09:00	7-Sep-21	17:00		
46	PLANNED	OCC_546	MP_SLDC	220KV-BHANPURA-MP-SUWASARA-MP	D	FOR LINE MAINTENANCE WORK	8-Sep-21	08:00	8-Sep-21	18:00	NR drawal restriction required up to 150 MW(max)	
47	PLANNED	OCC_546	MP_SLDC	220KV-MEHGAON-MP-AURIYA	D	FOR LINE MAINTENANCE WORK	8-Sep-21	09:00	8-Sep-21	17:00		
48	PLANNED	OCC_546	MP_SLDC	220KV INDORE-PG -UJJAIN-MP-1	D	FOR LINE MAINTENANCE WORK	9-Sep-21	8:00	9-Sep-21	18:00		
49	PLANNED	OCC_546	MP_SLDC	220KV-GWALIOR-PG-GWALIOR-II-MP-1	D	FOR BAY EQUIPMENT MAINTENANCE AND TESTING WORK	9-Sep-21	10:00	9-Sep-21	17:00		
50	PLANNED	OCC_546	MP_SLDC	220KV-GWALIOR-PG-GWALIOR-II-MP-2	D	FOR BAY EQUIPMENT MAINTENANCE AND TESTING WORK	10-Sep-21	10:00	10-Sep-21	17:00		
51	PLANNED	OCC_546	MP_SLDC	220KV-DAMOH-PG-TIKAMGARH-MP-1	D	FOR LINE MAINTENANCE WORK	13-Sep-21	09:00	13-Sep-21	18:00		
52	PLANNED	OCC_546	MP_SLDC	220KV-MORENA-MP-ADANI	D	FOR LINE MAINTENANCE WORK	13-Sep-21	09:00	13-Sep-21	17:00		
53	PLANNED	OCC_546	MP_SLDC	220KV-SABALGARH-MP-MORENA	D	FOR LINE MAINTENANCE WORK	13-Sep-21	9:00	13-Sep-21	17:00		
54	PLANNED	OCC_546	MP_SLDC	220KV-SUWASARA-MP-NIPANIYA	D	FOR LINE MAINTENANCE WORK	13-Sep-21	8:00	13-Sep-21	18:00	NR drawal restriction required up to 150 MW(max)	
55	PLANNED	OCC_546	MP_SLDC	220KV-KHANDWA-PG-CHHANERA-MP-1	D	FOR LINE MAINTENANCE WORK	14-Sep-21	08:00	14-Sep-21	18:00		
56	PLANNED	OCC_546	MP_SLDC	220KV-DAMOH-PG-TIKAMGARH-MP-1	D	FOR LINE MAINTENANCE WORK	15-Sep-21	09:00	15-Sep-21	18:00		
57	PLANNED	OCC_546	MP_SLDC	220KV INDORE-PG -UJJAIN-MP-1	D	FOR LINE MAINTENANCE WORK	16-Sep-21	08:00	16-Sep-21	18:00		
58	PLANNED	OCC_546	MP_SLDC	220KV-SATPURA-BETUL-PG	D	FOR LINE MAINTENANCE WORK	16-Sep-21	09:00	16-Sep-21	17:00		
59	PLANNED	OCC_546	MP_SLDC	220KV-KHANDWA-PG-CHHANERA-MP-2	D	FOR LINE MAINTENANCE WORK	17-Sep-21	08:00	17-Sep-21	18:00		
60	PLANNED	OCC_546	MP_SLDC	220KV-OMKARESHWAR- KHANDWA-PG	D	FOR LINE MAINTENANCE WORK	18-Sep-21	08:00	18-Sep-21	18:00		
61	PLANNED	OCC_546	MP_SLDC	220KV-PANDHURNA-MP-BETUL-PG	D	FOR LINE MAINTENANCE WORK	18-Sep-21	09:00	18-Sep-21	17:00		
62	PLANNED	OCC_546	MP_SLDC	220KV-SATNA(PGCIL)-CHHATARPUR-MP-1	D	FOR LINE MAINTENANCE WORK	18-Sep-21	09:00	18-Sep-21	18:00		
63	PLANNED	OCC_546	MP_SLDC	220KV-GWALIOR-PG-MAHALGAON-MP-1	D	FOR BAY EQUIPMENT MAINTENANCE AND TESTING WORK	20-Sep-21	10:00	20-Sep-21	17:00		
64	PLANNED	OCC_546	MP_SLDC	220KV-KHANDWA-PG-CHHEGAON-MP-2	D	FOR LINE MAINTENANCE WORK	20-Sep-21	08:00	20-Sep-21	18:00		
65	PLANNED	OCC_546	MP_SLDC	220KV-SATNA(PGCIL)-CHHATARPUR-MP-1	D	FOR LINE MAINTENANCE WORK	20-Sep-21	9:00	20-Sep-21	18:00		
66	PLANNED	OCC_546	MP_SLDC	220KV-DAMOH-PG-SAGAR-MP-1	D	FOR LINE MAINTENANCE WORK	21-Sep-21	09:00	21-Sep-21	18:00		
67	PLANNED	OCC_546	MP_SLDC	220KV-GWALIOR-PG-MAHALGAON-MP-2	D	FOR BAY EQUIPMENT MAINTENANCE AND TESTING WORK	21-Sep-21	10:00	21-Sep-21	17:00		
68	PLANNED	OCC_546	MP_SLDC	220KV-GWALIOR-PG-MAHALGAON-MP-2	D	220KV MAIN BUS MAINTENANCE & BUS TIE WORK	21-Sep-21	10:00	21-Sep-21	17:00		
69	PLANNED	OCC_546	MP_SLDC	132KV-KIRNAPUR-MP-DONGARGARH-CG	D	FOR LINE MAINTENANCE WORK	22-Sep-21	9:00	22-Sep-21	18:00		

Sr. No	Request Type	OCC Number	Name of Requesting Agency	Line / Element	D/C	reason	From	time	to	Time	Remarks	OCC-Remarks
70	PLANNED	OCC_546	MP_SLDC	220KV-DAMOH-PG-SAGAR-MP-1	D	FOR LINE MAINTENANCE WORK	22-Sep-21	09:00	22-Sep-21	18:00		
71	PLANNED	OCC_546	MP_SLDC	220KV-GWALIOR-PG-MALANPUR-MP-1	D	FOR LINE MAINTENANCE WORK	22-Sep-21	09:00	22-Sep-21	17:00		
72	PLANNED	OCC_546	MP_SLDC	220KV-SATPURA-BETUL-PG	D	FOR LINE MAINTENANCE WORK	22-Sep-21	9:00	22-Sep-21	17:00		
73	PLANNED	OCC_546	MP_SLDC	220KV-BHANPURA-MP-RANPUR-PG-RJ	D	FOR LINE MAINTENANCE WORK	23-Sep-21	08:00	23-Sep-21	18:00	NR drawal restriction required up to 150 MW(max)	
74	PLANNED	OCC_546	MP_SLDC	220KV-GWALIOR-PG-MAHALGAON-MP-1	D	220KV MAIN BUS MAINTENANCE & BUS TIE WORK	23-Sep-21	10:00	23-Sep-21	17:00		
75	PLANNED	OCC_546	MP_SLDC	220KV-DAMOH-PG-SAGAR-MP-2	D	FOR LINE MAINTENANCE WORK	24-Sep-21	09:00	24-Sep-21	18:00		
76	PLANNED	OCC_546	MP_SLDC	220KV-GWALIOR-PG-MALANPUR-MP-2	D	FOR LINE MAINTENANCE WORK	24-Sep-21	09:00	24-Sep-21	17:00		
77	PLANNED	OCC_546	MP_SLDC	220KV-PANDHURNA-MP-BETUL-PG	D	FOR LINE MAINTENANCE WORK	24-Sep-21	09:00	24-Sep-21	17:00		
78	PLANNED	OCC_546	MP_SLDC	220KV-ANOOPPUR-MP-KOTMIKALA-1	D	FOR LINE MAINTENANCE WORK	25-Sep-21	10:00	25-Sep-21	17:00		
79	PLANNED	OCC_546	MP_SLDC	220KV-DAMOH-PG-SAGAR-MP-2	D	FOR LINE MAINTENANCE WORK	25-Sep-21	09:00	25-Sep-21	18:00		
80	PLANNED	OCC_546	MP_SLDC	220KV-ANOOPPUR-MP-KOTMIKALA-2	D	FOR LINE MAINTENANCE WORK	27-Sep-21	10:00	27-Sep-21	17:00		
81	PLANNED	OCC_546	MP_SLDC	220KV-BINA-PG-SHIVPURI	D	FOR LINE MAINTENANCE WORK	27-Sep-21	09:00	27-Sep-21	17:00		
82	PLANNED	OCC_546	MP_SLDC	220KV-BHANPURA-MP-NIPANIYA	D	FOR LINE MAINTENANCE WORK	28-Sep-21	8:00	28-Sep-21	18:00	NR drawal restriction required up to 150 MW(max)	
83	PLANNED	OCC_546	MP_SLDC	220KV-BHANPURA-MP-MODAK	D	FOR LINE MAINTENANCE WORK	30-Sep-21	8:00	30-Sep-21	18:00	NR drawal restriction required up to 150 MW(max)	

E.E.(SLDC)