

WRPC OCC APPROVED SHUTDOWNS FOR MAY 2017

ALL INTRA STATE ENTITIES ARE REQUESTED TO GIVE THEIR READINESS FOR AVAILING SHUTDOWN ON D-3 BASIS ELSE THE SHUTDOWN MAY BE TREATED AS DEEMED CANCEL

Sr No	KV	Line / Element	From	To	Basis	Reason	System	Agency	Type	Site		
1	220	Chhegeon – Khandwa # 1	01/05/2017	06:00:00	31/05/2017	18:00:00	Daily	Online replacement of E/W with OPGW. A/R shall be kept in non auto mode	MPPTCL	WR-II	C	ULDC
2	220	Barwaha –Chhegeon (MPPTCL) # 1	01/05/2017	06:00:00	31/05/2017	18:00:00	Daily	Online replacement of E/W with OPGW. A/R shall be kept in non auto mode	MPPTCL	WR-II	C	ULDC
3	220	Seoni- Seoni (MPPTCL)-1	01/05/2017	06:00:00	31/05/2017	18:00:00	Daily	Online replacement of E/W with OPGW. A/R shall be kept in non auto mode	MPPTCL	WR-II	C	ULDC
4	220	400kV Bina(MPPTCL)-220 kV Bina (MPPTCL)-1	01/05/2017	06:00:00	31/05/2017	18:00:00	Daily	Online replacement of E/W with OPGW. A/R shall be kept in non auto mode	MPPTCL	WR-II	C	ULDC
5	400	SSP-Rajgarh-1	01/05/2017	06:00:00	05/05/2017	18:00:00	Daily	For Replacement of Defective Disc Insulator String	MPPTCL/SSP	MPPTCL		
6	220	220KV SAGAR-PGCIL(Damoh)	02/05/2017	06:00:00	02/05/2017	15:00:00	daily	LINE MAINTENANCE WORK	MPPTCL	MPPTCL	R	
7	400	400 KV JULWANIA-SSTPS	03/05/2017	08:00:00	03/05/2017	17:00:00	daily	LINE MAINTENANCE WORK	MPPTCL	MPPTCL	R	
8	220	220 KV RAJGARH(PG)- I/C FEEDER -I	03/05/2017	06:00:00	03/05/2017	14:00:00	daily	LINE MAINTENANCE WORK	MPPTCL	MPPTCL	R	
9	400	400KV BINA-BHOPAL -I	04/05/2017	06:00:00	04/05/2017	14:00:00	daily	LINE MAINTENANCE WORK	MPPTCL	MPPTCL	R	
10	400	400KV ISP-INDORE -II	04/05/2017	08:00:00	05/05/2017	18:00:00	CONTINUOUS	PREMANSOON MAINTENANCE WORK & CB MAINTENANCE WORK	MPPTCL	NHDC(ISP)	R	
11	400	Jaypee - Bina MPPTCL	04/05/2017	06:00:00	04/05/2017	17:00:00	Daily	Outage required to attend low clearnace problem due heavy induction during execution.	JAYPEE	WR-II	R	
12	220	220 KV MALANPUR-PGCIL-I	04/05/2017	06:00:00	04/05/2017	14:00:00	daily	LINE MAINTENANCE WORK	MPPTCL	MPPTCL	R	
13	220	220 KV RAJGARH(PG)- I/C FEEDER -II	04/05/2017	06:00:00	04/05/2017	14:00:00	daily	LINE MAINTENANCE WORK	MPPTCL	MPPTCL	R	
14	400	400 KV JULWANIA-CHHEGAON	05/05/2017	08:00:00	05/05/2017	17:00:00	daily	PREMANSOON MAINTENANCE WORK & REPLACEMENT OF DAMAGED INSULATOR	MPPTCL	MPPTCL	R	
15	400	400 KV CHHEGOAN-MALWA(Singhaji)	05/05/2017	06:00:00	05/05/2017	15:00:00	daily	LINE MAINTENANCE WORK	MPPTCL	MPPTCL	R	
16	400	400KV SEONI -BHILAI-S/c	05/05/2017	06:00:00	05/05/2017	15:00:00	daily	LINE MAINTENANCE WORK	MPPTCL	MPPTCL	R	
17	220	220 KV MALANPUR-Gwalior-II	05/05/2017	06:00:00	05/05/2017	14:00:00	daily	LINE MAINTENANCE WORK	MPPTCL	MPPTCL	R	
18	220	220 KV DHAR-RAJGARH-S/c	05/05/2017	06:00:00	05/05/2017	14:00:00	daily	LINE MAINTENANCE WORK	MPPTCL	MPPTCL	R	
19	220	220KV Damoh-Tikamgarh-S/c	05/05/2017	06:00:00	05/05/2017	15:00:00	daily	LINE MAINTENANCE WORK	MPPTCL	MPPTCL	R	
20	400	400 KV CHHEGOAN-MALWA	06/05/2017	06:00:00	06/05/2017	15:00:00	daily	LINE MAINTENANCE WORK	MPPTCL	MPPTCL	R	
21	400	400KV BINA-BHOPAL -II	06/05/2017	06:00:00	06/05/2017	14:00:00	daily	LINE MAINTENANCE WORK	MPPTCL	MPPTCL	R	
22	220	220 KV PITHAMPUR-RAJGARH	06/05/2017	06:00:00	06/05/2017	14:00:00	daily	LINE MAINTENANCE WORK	MPPTCL	MPPTCL	R	
23	220	220 kV SEONI-SEONI I	06/05/2017	08:00:00	06/05/2017	18:00:00	Daily	For AMP testing work	MPPTCL	WRTS-I	R	Line
24	400	SSP-Rajgarh-2	06/05/2017	06:00:00	10/05/2017	18:00:00	Daily	For Replacement of Defective Disc Insulator String	MPPTCL/SSP	MPPTCL		

25	400	400 KV JULWANIA- 315 MVA (CGL) ICT-I	08/05/2017	08:00:00	08/05/2017	17:00:00	DAILY	PREMANSOON MAINTENANCE WORK	MPPTCL	MPPTCL	R	
26	400	400 KV BINA 50 MVAR LINE REACTOR -I	08/05/2017	06:00:00	08/05/2017	14:00:00	DAILY	PREMANSOON MAINTENANCE WORK	MPPTCL	MPPTCL	R	
27	220	220 KV HOSHANGABAD-PGCIL	08/05/2017	06:00:00	08/05/2017	14:00:00	daily	LINE MAINTENANCE WORK	MPPTCL	MPPTCL	R	
28	400	400 KV JULWANIA- 315 MVA (CGL) ICT-I	09/05/2017	08:00:00	09/05/2017	17:00:00	DAILY	PREMANSOON MAINTENANCE WORK	MPPTCL	MPPTCL	R	
29	400	400 KV NAGDA 50 MVAR BUS REACTOR	09/05/2017	08:00:00	09/05/2017	17:00:00	DAILY	PREMANSOON MAINTENANCE WORK	MPPTCL	MPPTCL	R	
30	400	400KV BINA-BPSCL	09/05/2017	06:00:00	09/05/2017	14:00:00	daily	LINE MAINTENANCE WORK	MPPTCL	MPPTCL	R	
31	220	220 KV ITARSI-Itarsi	09/05/2017	06:00:00	09/05/2017	14:00:00	daily	LINE MAINTENANCE WORK	MPPTCL	MPPTCL	R	
32	220	220 KV MALANPUR - AURAIYA CKT	10/05/2017	06:00:00	10/05/2017	14:00:00	daily	LINE MAINTENANCE WORK	MPPTCL	MPPTCL	R	
33	400	400 KV JULWANIA- 315 MVA (EMCO) ICT-II	11/05/2017	08:00:00	11/05/2017	17:00:00	DAILY	PREMANSOON MAINTENANCE WORK	MPPTCL	MPPTCL	R	
34	400	400 KV NAGDA 125 MVAR BUS REACTOR	11/05/2017	08:00:00	11/05/2017	17:00:00	DAILY	PREMANSOON MAINTENANCE WORK	MPPTCL	MPPTCL	R	
35	400	400 KV BHOPAL-BINA -II	11/05/2017	06:00:00	11/05/2017	14:00:00	daily	PREMANSOON MAINTENANCE WORK	MPPTCL	MPPTCL	R	
36	400	400 KV ISP-SARNI	11/05/2017	08:00:00	12/05/2017	18:00:00	CONTINU OUS	PREMANSOON MAINTENANCE WORK & CB MAINTENANCE WORK	MPPTCL	NHDC(ISP)	R	
37	400	400KV DAMOH- KATNI	11/05/2017	10:00:00	11/05/2017	17:00:00	daily	LINE MAINTENANCE WORK	MPPTCL	MPPTCL	R	
38	400	SSP-Rajgarh-1	11/05/2017	06:00:00	15/05/2017	18:00:00	Daily	For Replacement of Defective Disc Insulator String	MPPTCL/SSP	MPPTCL		
39	400	400 KV JULWANIA- 315 MVA (EMCO) ICT-II	12/05/2017	08:00:00	12/05/2017	17:00:00	DAILY	PREMANSOON MAINTENANCE WORK	MPPTCL	MPPTCL	R	
40	400	400 KV BHOPAL 80 MVAR BUS REACTOR - I	12/05/2017	06:00:00	12/05/2017	14:00:00	DAILY	PREMANSOON MAINTENANCE WORK	MPPTCL	MPPTCL	R	
41	400	400KV SEONI -SARNI	12/05/2017	06:00:00	12/05/2017	15:00:00	daily	LINE MAINTENANCE WORK	MPPTCL	MPPTCL	R	
42	400	400 KV INDORE-NAGDA	13/05/2017	06:00:00	13/05/2017	17:00:00	daily	LINE MAINTENANCE WORK	MPPTCL	MPPTCL	R	
43	400	400 KV BHOPAL 80 MVAR BUS REACTOR -II	15/05/2017	06:00:00	15/05/2017	15:00:00	DAILY	PREMANSOON MAINTENANCE WORK	MPPTCL	MPPTCL	R	
44	400	400 KV BINA 50 MVAR LINE REACTOR -II of Bina-Bhopal	15/05/2017	06:00:00	15/05/2017	14:00:00	DAILY	PREMANSOON MAINTENANCE WORK	MPPTCL	MPPTCL	R	
45	400	400 KV TBC AT 400KV JULWANIA S/S	15/05/2017	08:00:00	15/05/2017	17:00:00	daily	LINE MAINTENANCE WORK	MPPTCL	MPPTCL	R	
46	400	400 KV MAIN BUS-I AT 400KV INDORE	15/05/2017	06:00:00	15/05/2017	14:00:00	daily	MAINTENANCE & RELAY TESTING WORK	MPPTCL	MPPTCL	R	
47	220	220 KV MEHGOAN - AURAIYA CKT	15/05/2017	06:00:00	15/05/2017	14:00:00	daily	LINE MAINTENANCE WORK	MPPTCL	MPPTCL	R	
48	400	400 KV BUS TIE AT 400KV JULWANIA S/S	16/05/2017	08:00:00	16/05/2017	17:00:00	daily	LINE MAINTENANCE WORK	MPPTCL	MPPTCL	R	
49	400	400 KV MAIN BUS-I AT 400KV INDORE	16/05/2017	06:00:00	16/05/2017	14:00:00	daily	MAINTENANCE & RELAY TESTING WORK	MPPTCL	MPPTCL	R	
50	220	220 KV RAJGARH-SHUJALPUR(PGCIL)-I	16/05/2017	06:00:00	16/05/2017	14:00:00	daily	LINE MAINTENANCE WORK	MPPTCL	MPPTCL	R	
51	220	220KV SEONI-CHHINDWARA-1	16/05/2017	06:00:00	16/05/2017	15:00:00	daily	LINE MAINTENANCE WORK	MPPTCL	MPPTCL	R	
52	400	SSP-Rajgarh-2	16/05/2017	06:00:00	20/05/2017	18:00:00	Daily	For Replacement of Defective Disc Insulator String	MPPTCL/SSP	MPPTCL		
53	400	400 KV ISP-NAGDA AT 400 KV ISP S/S	17/05/2017	08:00:00	18/05/2017	18:00:00	CONTINU OUS	MAINTENANCE WORK & REPLACEMENT OF SPRING ISOLATER & LINE MAINTENANCE WORK	MPPTCL	NHDC(ISP)	R	
54	400	400 KV JULWANIA 50 MVAR BUS REACTOR	17/05/2017	06:00:00	17/05/2017	15:00:00	DAILY	PREMANSOON MAINTENANCE WORK	MPPTCL	MPPTCL	R	
55	220	220 KV BINA(PGCIL)-SHIVPURI	17/05/2017	06:00:00	17/05/2017	14:00:00	daily	LINE MAINTENANCE WORK	MPPTCL	MPPTCL	R	
56	400	400 KV NAGDA- 315 MVA (BHEL) ICT-II	18/05/2017	08:00:00	20/05/2017	17:00:00	CONTINU OUS	FOR REPLACEMENT OF BAY ISOLATORS AND COMPLETE PAINTING OF ICT & ITS ACCESSORIES	MPPTCL	MPPTCL	R	

57	400	400 KV BINA- 315 MVA (BHEL) ICT-III	18/05/2017	06:00:00	18/05/2017	14:00:00	DAILY	PREMANSOON MAINTENANCE WORK	MPPTCL	MPPTCL	R	
58	400	400 KV NAGDA-RAJGARH-I	18/05/2017	06:00:00	18/05/2017	15:00:00	daily	PREMANSOON MAINTENANCE WORK	MPPTCL	MPPTCL	R	
59	400	400 KV MAIN BUS-II AT 400KV INDORE	18/05/2017	06:00:00	18/05/2017	14:00:00	daily	MAINTENANCE & RELAY TESTING WORK	MPPTCL	MPPTCL	R	
60	220	200 KV PADURNA-KALMESHVAR	18/05/2017	06:00:00	18/05/2017	15:00:00	daily	LINE MAINTENANCE WORK	MPPTCL	MPPTCL	R	
61	220	220KV DAMOH-DAMOHI/C -I	18/05/2017	06:00:00	18/05/2017	15:00:00	daily	LINE MAINTENANCE WORK	MPPTCL	MPPTCL	R	
62	400	400 KV MAIN BUS II AT 400 KV NAGDA	19/05/2017	08:00:00	21/05/2017	18:00:00	CONTINUOUS	REPLACEMENT OF PENTAGRAPH ISOLATORS OF COMPLETE MAINTENANCE OF BUS & BUS CVT	MPPTCL	MPPTCL	R	
63	400	400 KV NAGDA-RAJGARH-II	19/05/2017	06:00:00	19/05/2017	15:00:00	daily	PREMANSOON MAINTENANCE WORK	MPPTCL	MPPTCL	R	
64	400	400 KV BINA- 315 MVA (BHEL) ICT-II	22/05/2017	06:00:00	22/05/2017	14:00:00	DAILY	PREMANSOON MAINTENANCE WORK	MPPTCL	MPPTCL	R	
65	400	400 KV MAIN BUS I AT 400 KV NAGDA	22/05/2017	08:00:00	23/05/2017	17:00:00	CONTINUOUS	REPLACEMENT OF PENTAGRAPH ISOLATORS OF COMPLETE MAINTENANCE OF BUS & BUS CVT	MPPTCL	MPPTCL	R	
66	400	400KV BUS-B & BUS COUPLER AT 400 KV ISP S/S	23/05/2017	08:00:00	24/05/2017	17:00:00	CONTINUOUS	MAINTENANCE WORK	NHDC(ISP)	NHDC(ISP)		
67	400	400 KV BINA 50 MVAR BUS REACTOR	23/05/2017	06:00:00	23/05/2017	14:00:00	DAILY	PREMANSOON MAINTENANCE WORK	MPPTCL	MPPTCL	R	
68	400	400KV RAJGARH-SSP -I	23/05/2017	06:00:00	23/05/2017	14:00:00	daily	LINE MAINTENANCE WORK	MPPTCL	MPPTCL	R	
69	220	220 KV RAJGARH-SHUJALPUR(PGCIL)-II	23/05/2017	06:00:00	23/05/2017	14:00:00	daily	LINE MAINTENANCE WORK	MPPTCL	MPPTCL	R	
70	220	220KV ANNUPPUR-KOTMIKALA-I	23/05/2017	06:00:00	23/05/2017	15:00:00	daily	LINE MAINTENANCE WORK	MPPTCL	MPPTCL	R	
71	220	220KV DAMOH-DAMOHI/C -II	23/05/2017	06:00:00	23/05/2017	15:00:00	daily	LINE MAINTENANCE WORK	MPPTCL	MPPTCL	R	
72	400	400 KV NAGDA- 315 MVA (BHEL) ICT-III	24/05/2017	08:00:00	26/05/2017	17:00:00	CONTINUOUS	FOR REPLACEMENT OF BAY ISOLATORS AND COMPLETE PAINTING OF ICT & ITS ACCESSORIES	MPPTCL	MPPTCL	R	
73	400	400 KV MAIN BUS-II AT 400KV INDORE	24/05/2017	06:00:00	24/05/2017	14:00:00	daily	MAINTENANCE & RELAY TESTING WORK	MPPTCL	MPPTCL	R	
74	400	400KV RAJGARH-SSP -II	24/05/2017	06:00:00	24/05/2017	14:00:00	daily	LINE MAINTENANCE WORK	MPPTCL	MPPTCL	R	
75	220	220 KV SHUJALPUR-I/C FEEDER -I	24/05/2017	06:00:00	24/05/2017	14:00:00	daily	LINE MAINTENANCE WORK	MPPTCL	MPPTCL	R	
76	400	400KV BUS-A AT 400KV ISP S/S	25/05/2017	08:00:00	26/05/2017	18:00:00	CONTINUOUS	MAINTENANCE WORK	NHDC(ISP)	NHDC(ISP)	R	
77	400	400 KV BINA 25 MVAR LINE REACTOR -I	25/05/2017	06:00:00	25/05/2017	14:00:00	DAILY	PREMANSOON MAINTENANCE WORK	MPPTCL	MPPTCL	R	
78	220	220 KV BAROD-KOTA	25/05/2017	06:00:00	25/05/2017	15:00:00	daily	LINE MAINTENANCE WORK	MPPTCL	MPPTCL	R	
79	220	220 KV SHUJALPUR-I/C FEEDER -II	25/05/2017	06:00:00	25/05/2017	14:00:00	daily	LINE MAINTENANCE WORK	MPPTCL	MPPTCL	R	
80	220	220 KV BAROD-MODAK	26/05/2017	06:00:00	26/05/2017	15:00:00	daily	LINE MAINTENANCE WORK	MPPTCL	MPPTCL	R	
81	400	400 KV ISP-INDORE -I	27/05/2017	08:00:00	28/05/2017	17:00:00	CONTINUOUS	PREMANSOON MAINTENANCE WORK & CB MAINTENANCE	MPPTCL	NHDC(ISP)	R	
82	400	400KV BUS#I at MPPTCL, Indore	27/05/2017	10:00:00	28/05/2017	18:00:00	Continuou s	For replacement of Itarsi ckt #II, Bus #I isolator	MPPTCL	WR-II	R	INDORE
83	400	400 KV BINA 25 MVAR LINE REACTOR -II	27/05/2017	06:00:00	27/05/2017	14:00:00	DAILY	PREMANSOON MAINTENANCE WORK	MPPTCL	MPPTCL	R	
84	400	400KV BUS#II at MPPTCL, Indore	29/05/2017	10:00:00	30/05/2017	18:00:00	Continuou s	For replacement of itarsi ckt #I, Bus #II isolator	MPPTCL	WR-II	R	INDORE
85	400	400 KV BHOPAL- 315 MVA (BHEL) ICT-II	29/05/2017	06:00:00	29/05/2017	14:00:00	DAILY	PREMANSOON MAINTENANCE WORK	MPPTCL	MPPTCL	R	
86	220	220KV ANNUPPUR-KOTMIKALA-II	29/05/2017	06:00:00	29/05/2017	15:00:00	daily	LINE MAINTENANCE WORK	MPPTCL	MPPTCL	R	
87	400	Seoni - Sarni S/C	30/05/2017	08:00:00	31/05/2017	18:00:00	Continuou s	Stringing of new 765kV Gadarwara - Warora line	MPPTCL	POWERGRID-WR-II	C	
88	400	400 KV BHOPAL- 315 MVA (BHEL) ICT-II	30/05/2017	06:00:00	30/05/2017	14:00:00	DAILY	PREMANSOON MAINTENANCE WORK	MPPTCL	MPPTCL	R	
89	220	220 KV BINA-Bina PG-S/c	30/05/2017	06:00:00	30/05/2017	14:00:00	daily	LINE MAINTENANCE WORK	MPPTCL	MPPTCL	R	