

SUPPLEMENTRY AGENDA FOR 47TH OCC MEETING

Omkareshwar Power Station vide letter no. NHDC/3/OSP/O&M/06/33/2263 has submitted the following agenda points for inclusion in 47th OCC meeting scheduled to be held on 25.08.15.

SA1 :- Discrepancy in the PAF of OSP from 14th February 2015 to 17th February 2015 :- The matter of discrepancy in the PAF of OSPS from 14th Feb 15 to 17th Feb 15 was raised in WRPC'S Operation Coordination Committee forum, for suitable direction in the matter in its 473th meeting. Member Secretary WRPC stated that this was an issue with PAF Certification and does not pertain to operation. MS, WRPC suggested that NHDC to take the matter in State OCC meeting and if issue is not resolves, NHDC may like to bring it to the notice of appropriate regulator.

Omareshwar Power Station is run of river type Hydro Power Station of NHDC Limited and it was operating at restricted reservoir level of EL 189 M (before 12/04/2015) utilizing the water released from Indira Sagar Power Station.

Madhya Pradesh Power Transmission Company Limited is the sole beneficiary of NHDC Limited. Collector, Khandwa has been made Nodal Officer of Govt. of MP for Co-ordination between NHDC Limited and Madhya Pradesh State Load Dispatch Centre for operation related matters of Indira Sagar Power Station & Omkareshwar Power Station Dams.

During festival period schedule i.r.o Nos. of machine and constant flow is decided jointly by SLDC & Collector Khandwa, the nodal officer.

During Mahashivratri festival in the period of 14.02.2015 to 17.02.2015 , constant schedule of 03 machines was furnished by SLDC and machines at Omkareshwar Power Station were strictly run as per the schedule given by SLDC. It was clearly mentioned in Capacity Declaration given by OSP that power station is capable of generating 396 MW for more than three hours but *"due to Maha Shivratri festival period 10.02.2015 to 18.02.2015 as communicated by Collector Khandwa, Nodal Officer vide letter no. 03/2015/न्या. लि./1359 dated 05.02.2015, constant machine schedule is essentially desirable"* and PAF was 100%.

During the period on 14.02.2015 to 17.02.2015 All the machines of OSPS were available and the water was also available to generate daily Declared Capacity (In Ex-Bus MW), the station can deliver for at least 3 Hours (As per CERC Tariff Regulation 2014-19). However in SEA for the month of FEB 2015 , MPLSDC had restricted the PAF of these even dates by verifying monthly PAF of OSPS as 91.07% against the actual monthly PAF of 100%, considering only 3 machines as available against the availability of all 8 Units at OSPS, which is not justify.

Hence observing above facts, kindly consider the issue of discrepancy in the PAF of OSPS from 14th Feb 15 to 17th Feb 15 in Agenda of OCC meeting.

SA-2 : Continuous outage of 220 KV line – 3 (OSP – Julwania) : Since last one year most of the time the 220 KV OSP _ Julwania line is kept open as per instruction of SLDC due to over voltage. Further it is to be mentioned that the said line was kept open throughout the month of July 2015 by SLDC. During monsoon 08 machines run at OSP and 04 lines are available to transmit the power. Outage of any one line out of these 04 lines may create trouble in transmitting the power generated through 08 units. Necessary action is required in this connection from MPPTCL & Other related agencies/ Parties.

SA 3 :Installation of ABT Meter system :- Following shut down is required for installation of new ABT Meters:-

- | | | |
|---------------------------|---|---|
| 1. OSP- Nimrani (Line#1) | - | 3 rd Sept 2015 – 5 th Sept 2015 |
| 2. OSP_ Barwaha (Line#2) | - | 7 th Sept 2015 – 9 th Sept 2015 |
| 3. OSP_ Julwania (Line#3) | - | 10 th Sept 2015 – 12 th Sept 2015 |
| 4. OSP_ Chhegaon (Line#4) | - | 14 th Sept 2015 – 15 th Sept 2015 |
| 5. OSP_ Khandwa (Line#5) | - | 17 th Sept 2015 – 19 th Sept 2015 |